

WATER QUALITY REPORT

Location: Akodha Village, Laksar

Ser No	Test Parameters	Test Result Before Treatment	Test Result WATSAN Terafil	Standard limits as per WHO guidelines (mg/L)
1.	Odor	Pale Yellow	Transparent	No Visible Colour
2.	Chromium as Cr ⁶⁺ (mg/L)	0.17	0	0.05
3.	Lead as Pb (mg/L)	0.16	0.0013	0.01
4.	Cadmium as Cd (mg/L)	2.56	0.0002	0.003
5.	Arsenic as As (mg/L)	Not tested	0.013	0.01
6.	Mercury as Hg (mg/L)	0.26	0.0017	0.006

